

May 13, 2021

Mr. James Hart
North Tonawanda City School District
Director of Facilities
176 Walck Road
North Tonawanda, New York 14120

RE: Investigation and Sampling of Drinking Water for Lead Concentrations

Dear Mr. Hart:

Included with this letter is Stohl Environmental LLC's report for the Water Sampling performed at the educational buildings of the North Tonawanda City School District, including:

- North Tonawanda High School – 405 Meadow Drive, Tonawanda, New York.

This report is prepared to assist the District in complying with the requirements of NYS regulations, *SUBPART 67-4: Lead Testing in School Drinking Water*, by identifying the sources of potable water with lead concentrations greater than the NYS "Action Level of 15 parts per billion (ppb)".

The Investigation and Sampling was performed on March 9, 2021. The Protocol for the Investigation followed the requirements of NYS regulations as well as USEPA Technical Guidance Document "3-T's for Reducing Lead in Drinking Water in Schools".

As detailed in Section 1.2 (*Executive Summary*) of the accompanying report, based upon the sampling and analysis performed, 36 sources of potable water in the High School have been identified as having lead concentrations in water above the NYS Action Level of 15 parts per billion. To comply with NYS regulations, Response actions as identified in this report by the District are required.

Thank you for the opportunity to be of service to North Tonawanda City School District.

Sincerely,
Stohl Environmental, LLC.



Eric Henderson Jr.
Senior Project Manager

**Investigation and Sampling
Of Sources of Potable Water
For Lead Concentrations**

Prepared for:

North Tonawanda City School District

Prepared by:



**3860 California Road, Orchard Park, New York 14127
PHONE (716) 312-0070 FAX (716) 312-8092
WWW.STOHLENVIRONMENTAL.COM**

Conditions as of March 9, 2021

Summary Tabulation

Lead in Drinking Water Investigation

- 1.1. Scope of Work and Sampling Protocol
- 1.2. Executive Summary of Sampling and Analysis
- 1.3. Response Actions Required Under NYS Regulations
- 1.4. Laboratory Analytical Reports by Building
- 1.5. Laboratory Certifications
- 1.6. Chains of Custody

1.1 Scope of Work and Sampling Protocol:

Stohl Environmental was retained by North Tonawanda City School District to perform sampling and analysis of potable water for elevated lead concentrations. Sampling was performed in the following buildings:

- North Tonawanda High School – 405 Meadow Drive, Tonawanda, New York.

Scope of Work:

Stohl Environmental was charged with collecting first-draw water samples from outlets within the High School. Outlets are defined in NYS regulations as: “a potable water fixture currently or potentially used for drinking or cooking purposes, including but not limited to a bubbler, drinking fountain, or faucets”.

Sampling Protocol:

In accordance with NYS regulations, ***Subpart 67-4: Lead Testing in School Drinking Water***, and the EPA guidance document, ***‘3Ts for Reducing Lead in Drinking Water in Schools’***, Stohl Environmental’s protocol can be summarized as follows:

- **First-draw samples** of 250 milliliters (mL) were collected from cold water outlets before any water was used. Sampling was coordinated with District representatives to assure that water was motionless in the pipes for a minimum of 8 hours, but not more than 18 hours before sample collection.
- **Laboratory Analysis:** Samples were submitted following strict chain-of-custody protocols to an independent laboratory approved by the NYS Department of Health’s Environmental Laboratory Approval Program (ELAP).

1.2 Executive Summary of Sampling and Analysis:

Total Number of Samples Collected by Building Classified by First Draw & Confirmatory Samples:

Building Name	Date of Sample Event	Total Number Samples Collected	First Draw Samples		Confirmatory Samples **	
			Number of Samples at or Below Action level of 15 ppb	Number of Samples Above Action Level of 15 ppb	Number of Samples at or Below Action level of 15 ppb	Number of Samples Above Action Level of 15 ppb
High School	3/9/2021	160	124	36	N/A	N/A

** Confirmatory samples are samples collected subsequent to "Step 1" First Draw samples to verify initial findings of lead contamination, to assist in problem assessment to determine remediation and/or verify that lead levels are at or below action level post-remediation.

Listing of Outlets Requiring Remediation

Locations of Outlets Analyzed above the NYS Action Level of 15 parts per billion based upon Analysis of First Draw Samples:

Sample #	Classroom or other Location	Fixture/Outlet type	Laboratory Analysis in ppb
185.1-31	Varsity Locker Room Right	Sink	22.4
185.1-35	New Gym Women's Locker Room Coach's Lav	Sink	24.3
185.1-52	Room 112	Sink	15.1
185.1-55	Boys Lav Outside 112 Right	Sink	39.7
185.1-62B	Corridor Outside 1 st Floor Women's Faculty	Bottle Fill	N/A
185.1-63	Girls Lav Outside Cafeteria Left	Sink	19.3
185.1-69	Room 160 Left	Sink	51.6
185.1-70	Room 160 Center	Sink	90.0
185.1-72	Room 160 Bubbler	Bubbler	18.8
185.1-77	Kitchen 3 Bay Left	Sink	20.5
185.1-82	Room 121	Sink	20.2
185.1-83	Room 123	Sink	28.6
185.1-84	Room 122	Sink	146
185.1-85	Room 125	Sink	60.0
185.1-86	Room 124	Sink	29.6
185.1-96	Girls Lav Outside 130 Left Most	Sink	26.8
185.1-166	Room 308 Left	Sink	112

Sample #	Classroom or other Location	Fixture/Outlet type	Laboratory Analysis in ppb
185.1-167	Room 308 Right	Sink	73.7
185.1-168	Room 307	Sink	152
185.1-169	Room 310	Sink	125
185.1-176	Boys Lav Outside 312 Right Most	Sink	41.3
185.1-177	Girl Lav Outside 312 Left Most	Sink	18.0
185.1-183	Room 319	Sink	132
185.1-193	Room 326 Right	Sink	19.2
185.1-194	Room 328	Sink	17.2
185.1-195	Room 330 North Faucet w/ Hose Attachment	Sink	37.7
185.1-198	Boy Lav Outside 332 Center	Sink	17.4
185.1-202	Girls Lav Outside 332 Left Most	Sink	22.9
185.1-204	Girls Lav Outside 332 Center	Sink	17.4
185.1-208	Room 332 White Sink Right	Sink	32.7
185.1-209	Room 332 Far Right	Sink	50.8
185.1-210	Room 332 Storage	Sink	285
185.1-211	Room 332 Teacher Desk	Sink	117
185.1-212	Room 336	Sink	389
185.1-219	Girls Lav Outside 214 Left Most	Sink	18.8
185.1-228	Men's Lav Outside 232 Right Most	Sink	N/A
185.1-230	Women's Lav Outside 232 Left Most	Sink	48.5
185.1-232	Women's Lav Outside 232 Center	Sink	21.9

N/A = Not Analyzed. The laboratory received the sample empty and was not able to be analyzed. Location should be resampled and analyzed at a later date.

1.3 Response Actions Required Under NYS Regulations, Section 67-4.4:

For outlets analyzed with a lead concentration in excess of the NYS Action Level, regulations require:

- (a) Prohibit use of the outlet until:
 - (1) a lead remediation plan is implemented to mitigate the lead level of such outlet; and
 - (2) test results indicate that the lead levels are at or below the action level;
- (b) provide building occupants with an adequate supply of potable water for drinking and cooking until remediation is performed;
- (c) report the test results to the local health department as soon as practicable, but no more than 1 business day after the school received the laboratory report; and
- (d) notify all staff and all persons in parental relation to students of the test results, in writing, as soon as practicable but no more than 10 business days after the school received the laboratory report.

1.4 Laboratory Analytical Reports by Building



Environmental Hazards Services, L.L.C.
 7469 Whitepine Rd
 Richmond, VA 23237
 Telephone: 800.347.4010

Lead in Drinking Water Analysis Report

Client: Stohl Environmental
 3860 California Road
 Orchard Park, NY 14127

Report Number: 21-03-03821
 Received Date: 03/17/2021
 Reported Date: 04/12/2021
 Sampled By: Christine Shultz
 Tech Certification #:

Project/Test Address: 2020L-185.1; North Tonawanda High School; 405 Meadow Drive; Tonawanda, NY

Client Number:
 33-5980

Laboratory Results

Fax Number:
 716-312-8092

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
21-03-03821-001	185.1-3	03/09/2021	BOYS DRESSING ROOM LEAD	4.16	04/09/2021	
21-03-03821-002	185.1-4	03/09/2021	BOYS DRESSING ROOM LEFT	2.86	04/09/2021	
21-03-03821-003	185.1-5	03/09/2021	BOYS DRESSING ROOM RIGHT	4.20	04/09/2021	
21-03-03821-004	185.1-6	03/09/2021	GIRLS DRESSING ROOM LEAD	4.36	04/09/2021	
21-03-03821-005	185.1-7	03/09/2021	GIRLS DRESSING ROOM LEFT	2.83	04/09/2021	
21-03-03821-006	185.1-8	03/09/2021	GIRLS DRESSING ROOM RIGHT	2.19	04/09/2021	
21-03-03821-007	185.1-9	03/09/2021	OUTSIDE DRESSING ROOMS	1.63	04/09/2021	
21-03-03821-008	185.1-11	03/09/2021	WOMEN'S GANG LAV OUTSIDE NEW GYM 2ND LEFT	1.01	04/09/2021	
21-03-03821-009	185.1-12	03/09/2021	WOMEN'S GANG LAV OUTSIDE NEW GYM 3RD LEFT	6.56	04/09/2021	
21-03-03821-010	185.1-13	03/09/2021	WOMEN'S GANG LAV OUTSIDE NEW GYM 3RD RIGHT	1.67	04/09/2021	

Environmental Hazards Services, L.L.C

Client Number: 33-5980
 Project/Test Address: 2020L-185.1; North Tonawanda High School; 405
 Meadow Drive; Tonawanda, NY

Report Number: 21-03-03821

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
21-03-03821-011	185.1-14	03/09/2021	WOMEN'S GANG LAV OUTSIDE NEW GYM 2ND RIGHT	4.81	04/09/2021	
21-03-03821-012	185.1-15	03/09/2021	WOMEN'S GANG LAV OUTSIDE NEW GYM RIGHT MOST	3.48	04/09/2021	
21-03-03821-013	185.1-16	03/09/2021	MEN'S GANG LAV OUTSIDE NEW GYM LEFT MOST	1.02	04/09/2021	
21-03-03821-014	185.1-17	03/09/2021	MEN'S GANG LAV OUTSIDE NEW GYM 2ND LEFT	2.18	04/09/2021	
21-03-03821-015	185.1-18	03/09/2021	MEN'S GANG LAV OUTSIDE NEW GYM 3RD LEFT	1.39	04/09/2021	
21-03-03821-016	185.1-19	03/09/2021	MEN'S GANG LAV OUTSIDE NEW GYM 3RD RIGHT	1.32	04/09/2021	
21-03-03821-017	185.1-20	03/09/2021	MEN'S GANG LAV OUTSIDE NEW GYM 2ND RIGHT	<1.00	04/09/2021	
21-03-03821-018	185.1-21	03/09/2021	MEN'S GANG LAV OUTSIDE NEW GYM RIGHT MOST	7.76	04/09/2021	
21-03-03821-019	185.1-22	03/09/2021	FOUNTAIN OUTSIDE GANGS LAV LEFT	<1.00	04/09/2021	
21-03-03821-020	185.1-23	03/09/2021	FOUNTAIN OUTSIDE GANGS LAV RIGHT	<1.00	04/09/2021	
21-03-03821-021	185.1-24	03/09/2021	SINGLE LAV OUTSIDE NEW GYM LEFT	3.27	04/09/2021	
21-03-03821-022	185.1-25	03/09/2021	W OFFICIALS	3.08	04/09/2021	
21-03-03821-023	185.1-26	03/09/2021	M OFFICIALS	2.82	04/09/2021	
21-03-03821-024	185.1-27A	03/09/2021	FOUNTAIN OUTSIDE NEW GYM	<1.00	04/09/2021	
21-03-03821-025	185.1-27B	03/09/2021	FOUNTAIN OUTSIDE NEW GYM	<1.00	04/09/2021	
21-03-03821-026	185.1-28	03/09/2021	COACH/TRAINER OFFICE LAV OUTSIDE NEW GYM	8.44	04/09/2021	
21-03-03821-027	185.1-29	03/09/2021	VARSITY LOCKER ROOM FOUNTAIN	1.97	04/09/2021	
21-03-03821-028	185.1-30	03/09/2021	VARSITY LOCKER ROOM LEFT	3.94	04/09/2021	

Environmental Hazards Services, L.L.C

Client Number: 33-5980

Report Number: 21-03-03821

Project/Test Address: 2020L-185.1; North Tonawanda High School; 405 Meadow Drive; Tonawanda, NY

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
21-03-03821-029	185.1-31	03/09/2021	VARSITY LOCKER ROOM RIGHT	22.4	04/09/2021	
21-03-03821-030	185.1-32	03/09/2021	NEW GYM MEN'S LOCKER COACH LAV	9.64	04/09/2021	
21-03-03821-031	185.1-33	03/09/2021	NEW GYM MEN'S LOCKER LEFT	3.21	04/09/2021	
21-03-03821-032	185.1-34	03/09/2021	NEW GYM MEN'S LOCKER RIGHT	2.67	04/09/2021	
21-03-03821-033	185.1-35	03/09/2021	NEW GYM WOMEN'S LOCKER COACH LAV	24.3	04/09/2021	
21-03-03821-034	185.1-36	03/09/2021	NEW GYM WOMEN'S LOCKER FOUNTAIN	<1.00	04/09/2021	
21-03-03821-035	185.1-37	03/09/2021	NEW GYM WOMEN'S LOCKER LEFT	2.24	04/09/2021	
21-03-03821-036	185.1-39	03/09/2021	NEW GYM WOMEN'S LOCKER RIGHT	7.19	04/09/2021	
21-03-03821-037	185.1-43	03/09/2021	OLD GYM BOYS LOCKER LEFT	13.2	04/09/2021	
21-03-03821-038	185.1-45	03/09/2021	OLD GYM BOYS LOCKER COACH OFFICE	8.85	04/09/2021	
21-03-03821-039	185.1-46	03/09/2021	FOUNTAIN OUTSIDE OLD GYM GIRLS	7.48	04/09/2021	
21-03-03821-040	185.1-47	03/09/2021	OLD GYM GIRLS LOCKER COACH OFFICE	7.91	04/09/2021	
21-03-03821-041	185.1-48	03/09/2021	OLD GYM GIRLS LOCKER LEFT	9.23	04/09/2021	
21-03-03821-042	185.1-49	03/09/2021	OLD GYM GIRLS LOCKER RIGHT	5.32	04/09/2021	
21-03-03821-043	185.1-50	03/09/2021	CORRIDOR OUTSIDE 112	1.68	04/09/2021	
21-03-03821-044	185.1-51	03/09/2021	LIBRARY	6.51	04/09/2021	
21-03-03821-045	185.1-52	03/09/2021	ROOM 112	15.1	04/09/2021	
21-03-03821-046	185.1-53	03/09/2021	BOYS LAV OUTSIDE 112 LEFT	3.39	04/09/2021	
21-03-03821-047	185.1-54	03/09/2021	BOYS LAV OUTSIDE 112 CENTER	8.46	04/09/2021	
21-03-03821-048	185.1-55	03/09/2021	BOYS LAV OUTSIDE 112 RIGHT	39.7	04/09/2021	

Environmental Hazards Services, L.L.C

Client Number: 33-5980
 Project/Test Address: 2020L-185.1; North Tonawanda High School; 405
 Meadow Drive; Tonawanda, NY

Report Number: 21-03-03821

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
21-03-03821-049	185.1-56	03/09/2021	GIRLS LAV OUTSIDE 114 LEFT	1.83	04/09/2021	
21-03-03821-050	185.1-57	03/09/2021	GIRLS LAV OUTSIDE 114 CENTER	3.10	04/09/2021	
21-03-03821-051	185.1-58	03/09/2021	GIRLS LAV OUTSIDE 114 RIGHT	2.36	04/09/2021	
21-03-03821-052	185.1-59	03/09/2021	1ST FLOOR MEN'S FACULTY	1.15	04/09/2021	
21-03-03821-053	185.1-60	03/09/2021	1ST FLOOR WOMEN'S FACULTY LEFT	2.85	04/09/2021	
21-03-03821-054	185.1-61	03/09/2021	1ST FLOOR WOMEN'S FACULTY RIGHT	<1.00	04/09/2021	
21-03-03821-055	185.1-62A	03/09/2021	CORRIDOR OUTSIDE 1ST FLOOR WOMEN'S FACULTY	1.72	04/09/2021	
21-03-03821-056	185.1-63	03/09/2021	GIRLS LAV OUTSIDE CAFETERIA LEFT	19.3	04/09/2021	
21-03-03821-057	185.1-65	03/09/2021	GIRLS LAV OUTSIDE CAFETERIA RIGHT	5.45	04/09/2021	
21-03-03821-058	185.1-66	03/09/2021	BOYS LAV OUTSIDE CAFETERIA LEFT	2.26	04/09/2021	
21-03-03821-059	185.1-68	03/09/2021	BOYS LAV OUTSIDE CAFETERIA RIGHT	7.87	04/09/2021	
21-03-03821-060	185.1-69	03/09/2021	ROOM 160 LEFT	51.6	04/09/2021	
21-03-03821-061	185.1-70	03/09/2021	ROOM 160 CENTER	90.0	04/09/2021	
21-03-03821-062	185.1-71	03/09/2021	ROOM 160 RIGHT	14.1	04/09/2021	
21-03-03821-063	185.1-72	03/09/2021	ROOM 160 BUBBLER	18.8	04/09/2021	
21-03-03821-064	185.1-73	03/09/2021	KITCHEN SERVING HANDWASH	1.11	04/09/2021	
21-03-03821-065	185.1-74	03/09/2021	KITCHEN DISH SPRAYER NORTH CAFE SIDE	1.14	04/09/2021	
21-03-03821-066	185.1-74.5	03/09/2021	KITCHEN SINGLE BAY NORTH CAFE SIDE	1.51	04/09/2021	
21-03-03821-067	185.1-75	03/09/2021	KITCHEN HANDWASH NORTH WALL CENTER ROOM	1.45	04/09/2021	

Environmental Hazards Services, L.L.C

Client Number: 33-5980

Report Number: 21-03-03821

Project/Test Address: 2020L-185.1; North Tonawanda High School; 405 Meadow Drive; Tonawanda, NY

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
21-03-03821-068	185.1-76	03/09/2021	KITCHEN SINGLE BAY ACROSS FROM 3 BAY	<1.00	04/09/2021	
21-03-03821-069	185.1-77	03/09/2021	KITCHEN 3 BAY LEFT	20.5	04/09/2021	
21-03-03821-070	185.1-77.5	03/09/2021	KITCHEN 3 BAY RIGHT	2.21	04/09/2021	
21-03-03821-071	185.1-78	03/09/2021	KITCHEN SINGLE BAY CENTER PREP	<1.00	04/09/2021	
21-03-03821-072	185.1-79	03/09/2021	KITCHEN HANDWASH SOUTH WALL CENTER ROOM	1.53	04/09/2021	
21-03-03821-073	185.1-80	03/09/2021	KITCHEN DISH SPRAYER SOUTH CAFE SIDE	2.66	04/09/2021	
21-03-03821-074	185.1-80.5	03/09/2021	KITCHEN SINGLE BAY SOUTH CAFE SIDE	2.07	04/09/2021	
21-03-03821-075	185.1-81	03/09/2021	GUIDANCE OFFICE	2.85	04/09/2021	
21-03-03821-076	185.1-82	03/09/2021	ROOM 121	20.2	04/09/2021	
21-03-03821-077	185.1-83	03/09/2021	ROOM 123	28.6	04/09/2021	
21-03-03821-078	185.1-84	03/09/2021	ROOM 122	146	04/09/2021	
21-03-03821-079	185.1-85	03/09/2021	ROOM 125	60.0	04/09/2021	
21-03-03821-080	185.1-86	03/09/2021	ROOM 124	29.6	04/09/2021	
21-03-03821-081	185.1-87	03/09/2021	ROOM 126A LEFT	9.88	04/09/2021	
21-03-03821-082	185.1-89	03/09/2021	ROOM 128	3.22	04/09/2021	
21-03-03821-083	185.1-90	03/10/2021	BOYS LAV OUTSIDE 130 LEFT MOST	5.48	04/09/2021	
21-03-03821-084	185.1-92	03/10/2021	BOYS LAV OUTSIDE 130 CENTER	8.85	04/09/2021	
21-03-03821-085	185.1-94	03/10/2021	BOYS LAV OUTSIDE 130 RIGHT MOST	9.64	04/09/2021	
21-03-03821-086	185.1-95A	03/10/2021	CORRIDOR OUTSIDE ROOM 130	2.49	04/09/2021	

Environmental Hazards Services, L.L.C

Client Number: 33-5980

Report Number: 21-03-03821

Project/Test Address: 2020L-185.1; North Tonawanda High School; 405 Meadow Drive; Tonawanda, NY

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
21-03-03821-087	185.1-95B	03/10/2021	CORRIDOR OUTSIDE ROOM 130	2.83	04/09/2021	
21-03-03821-088	185.1-96	03/10/2021	GIRLS LAV OUTSIDE 130 LEFT MOST	26.8	04/09/2021	
21-03-03821-089	185.1-98	03/10/2021	GIRLS LAV OUTSIDE 130 CENTER	12.0	04/09/2021	
21-03-03821-090	185.1-100	03/10/2021	GIRLS LAV OUTSIDE 130 RIGHT MOST	10.8	04/09/2021	
21-03-03821-091	185.1-101	03/10/2021	ROOM 130	4.39	04/09/2021	
21-03-03821-092	185.1-102	03/10/2021	ROOM 132 NORTHEAST	7.16	04/09/2021	
21-03-03821-093	185.1-103	03/10/2021	ROOM 132 SOUTHEAST	7.42	04/09/2021	
21-03-03821-094	185.1-104	03/10/2021	ROOM 132 SOUTHWEST	9.96	04/09/2021	
21-03-03821-095	185.1-105	03/10/2021	ROOM 132 NORTHWEST	3.58	04/09/2021	
21-03-03821-096	185.1-135	03/10/2021	SCIENCE WING CORRIDOR OUTSIDE FACULTY	<1.00	04/09/2021	
21-03-03821-097	185.1-136	03/10/2021	SCIENCE WING WOMEN'S FACULTY	<1.00	04/09/2021	
21-03-03821-098	185.1-137	03/10/2021	SCIENCE WING MEN'S FACULTY	<1.00	04/09/2021	
21-03-03821-099	185.1-138	03/10/2021	SCIENCE WING GIRLS LAV LEFT	<1.00	04/09/2021	
21-03-03821-100	185.1-140	03/10/2021	SCIENCE WING GIRLS LAV RIGHT	<1.00	04/09/2021	
21-03-03821-101	185.1-141	03/10/2021	SCIENCE WING BOYS LAV LEFT	<1.00	04/09/2021	
21-03-03821-102	185.1-141.5	03/10/2021	SCIENCE WING BOYS LAV CENTER	1.03	04/11/2021	
21-03-03821-103	185.1-142	03/10/2021	SCIENCE WING BOYS LAV RIGHT	<1.00	04/09/2021	
21-03-03821-104	185.1-143A	03/10/2021	SCIENCE WING CORRIDOR BETWEEN B/G LAVS	<1.00	04/09/2021	
21-03-03821-105	185.1-143B	03/10/2021	SCIENCE WING CORRIDOR BETWEEN B/G LAVS	<1.00	04/09/2021	
21-03-03821-106	185.1-149	03/10/2021	ROOM 151A	3.00	04/09/2021	

Environmental Hazards Services, L.L.C

Client Number: 33-5980

Report Number: 21-03-03821

Project/Test Address: 2020L-185.1; North Tonawanda High School; 405 Meadow Drive; Tonawanda, NY

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
21-03-03821-107	185.1-157	03/10/2021	ROOM 155A	2.68	04/09/2021	
21-03-03821-108	185.1-166	03/10/2021	ROOM 308 LEFT	112	04/09/2021	
21-03-03821-109	185.1-167	03/10/2021	ROOM 308 RIGHT	73.7	04/09/2021	
21-03-03821-110	185.1-168	03/10/2021	ROOM 307	152	04/09/2021	
21-03-03821-111	185.1-169	03/10/2021	ROOM 310	125	04/09/2021	
21-03-03821-112	185.1-170	03/10/2021	3RD FLOOR MEN'S FACULTY	2.99	04/09/2021	
21-03-03821-113	185.1-171	03/10/2021	3RD FLOOR WOMEN'S FACULTY	3.23	04/09/2021	
21-03-03821-114	185.1-172	03/10/2021	BOYS'LAV OUTSIDE 312 LEFT MOST	8.04	04/09/2021	
21-03-03821-115	185.1-174	03/10/2021	BOYS LAV OUTSIDE 312 CENTER	13.5	04/09/2021	
21-03-03821-116	185.1-176	03/10/2021	BOYS LAV OUTSIDE 312 RIGHT MOST	41.3	04/09/2021	
21-03-03821-117	185.1-177	03/10/2021	GIRLS LAV OUTSIDE 312 LEFT MOST	18.0	04/09/2021	
21-03-03821-118	185.1-179	03/10/2021	GIRLS LAV OUTSIDE 312 CENTER	8.41	04/09/2021	
21-03-03821-119	185.1-181	03/10/2021	GIRLS LAV OUTSIDE 312 RIGHT MOST	12.2	04/09/2021	
21-03-03821-120	185.1-182A	03/10/2021	CORRIDOR OUTSIDE 312 BETWEEN B/G LAVS	1.73	04/09/2021	
21-03-03821-121	185.1-182B	03/10/2021	CORRIDOR OUTSIDE 312 BETWEEN B/G LAVS	1.63	04/09/2021	
21-03-03821-122	185.1-183	03/10/2021	ROOM 319	132	04/09/2021	
21-03-03821-123	185.1-184	03/10/2021	ROOM 322	12.6	04/09/2021	
21-03-03821-124	185.1-189	03/10/2021	ROOM 324 LEFT	10.3	04/09/2021	
21-03-03821-125	185.1-190	03/10/2021	ROOM 324 RIGHT	7.83	04/09/2021	
21-03-03821-126	185.1-192	03/10/2021	ROOM 326 LEFT	14.8	04/10/2021	

Environmental Hazards Services, L.L.C

Client Number: 33-5980

Report Number: 21-03-03821

Project/Test Address: 2020L-185.1; North Tonawanda High School; 405 Meadow Drive; Tonawanda, NY

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
21-03-03821-127	185.1-196	03/10/2021	ROOM 326 RIGHT	19.2	04/09/2021	
21-03-03821-128	185.1-194	03/10/2021	ROOM 328	17.2	04/09/2021	
21-03-03821-129	185.1-195	03/10/2021	ROOM 330 NORTH FAUCET W/ HOSE ATTACHMENT	37.7	04/09/2021	
21-03-03821-130	185.1-196	03/10/2021	BOYS LAV OUTSIDE 332 LEFT MOST	12.7	04/09/2021	
21-03-03821-131	185.1-198	03/10/2021	BOYS LAV OUTSIDE 332 CENTER	17.4	04/09/2021	
21-03-03821-132	185.1-200	03/10/2021	BOYS LAV OUTSIDE 332 RIGHT MOST	13.0	04/09/2021	
21-03-03821-133	185.1-201A	03/10/2021	CORRIDOR OUTSIDE 332 BETWEEN B/G LAVS	2.47	04/09/2021	
21-03-03821-134	185.1-201B	03/10/2021	CORRIDOR OUTSIDE 332 BETWEEN B/G LAVS	2.27	04/09/2021	
21-03-03821-135	185.1-202	03/10/2021	GIRLS LAV OUTSIDE 332 LEFT MOST	22.9	04/09/2021	
21-03-03821-136	185.1-204	03/10/2021	GIRLS LAV OUTSIDE 332 CENTER	17.4	04/09/2021	
21-03-03821-137	185.1-206	03/10/2021	GIRLS LAV OUTSIDE 332 RIGHT MOST	13.0	04/09/2021	
21-03-03821-138	185.1-207	03/10/2021	ROOM 332 WHITE SINK LEFT	10.9	04/09/2021	
21-03-03821-139	185.1-208	03/10/2021	ROOM 332 WHITE SINK RIGHT	32.7	04/09/2021	
21-03-03821-140	185.1-209	03/10/2021	ROOM 332 FAR RIGHT	50.8	04/09/2021	
21-03-03821-141	185.1-210	03/10/2021	ROOM 332 STORAGE	285	04/09/2021	
21-03-03821-142	185.1-211	03/10/2021	ROOM 332 TEACHER DESK	117	04/09/2021	
21-03-03821-143	185.1-212	03/10/2021	ROOM 336	389	04/09/2021	
21-03-03821-144	185.1-213	03/10/2021	BOYS LAV OUTSIDE 214 LEFT MOST	3.23	04/09/2021	
21-03-03821-145	185.1-215	03/10/2021	BOYS LAV OUTSIDE 214 CENTER	2.51	04/09/2021	
21-03-03821-146	185.1-217	03/10/2021	BOYS LAV OUTSIDE 214 RIGHT MOST	5.60	04/10/2021	

Environmental Hazards Services, L.L.C

Client Number: 33-5980

Report Number: 21-03-03821

Project/Test Address: 2020L-185.1; North Tonawanda High School; 405 Meadow Drive; Tonawanda, NY

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
21-03-03821-147	185.1-218A	03/10/2021	CORRIDOR OUTSIDE 214 BETWEEN B/G LAVS	1.68	04/09/2021	
21-03-03821-148	185.1-218B	03/10/2021	CORRIDOR OUTSIDE 214 BETWEEN B/G LAVS	1.52	04/09/2021	
21-03-03821-149	185.1-219	03/10/2021	GIRLS LAV OUTSIDE 214 LEFT MOST	18.8	04/09/2021	
21-03-03821-150	185.1-221	03/10/2021	GIRLS LAV OUTSIDE 214 CENTER	10.3	04/09/2021	
21-03-03821-151	185.1-223	03/10/2021	GIRLS LAV OUTSIDE 214 RIGHT MOST	8.36	04/09/2021	
21-03-03821-152	185.1-224	03/10/2021	MEN'S LAV OUTSIDE 232 LEFT MOST	9.55	04/09/2021	
21-03-03821-153	185.1-226	03/10/2021	MEN'S LAV OUTSIDE 232 CENTER	12.4	04/09/2021	
21-03-03821-154	185.1-229A	03/10/2021	CORRIDOR OUTSIDE 232 BETWEEN M/W LAVS	1.89	04/09/2021	
21-03-03821-155	185.1-229B	03/10/2021	CORRIDOR OUTSIDE 232 BETWEEN M/W LAVS	1.50	04/09/2021	
21-03-03821-156	185.1-230	03/10/2021	WOMEN'S LAV OUTSIDE 232 LEFT MOST	48.5	04/09/2021	
21-03-03821-157	185.1-232	03/10/2021	WOMEN'S LAV OUTSIDE 232 CENTER	21.9	04/09/2021	
21-03-03821-158	185.1-234	03/10/2021	WOMEN'S LAV OUTSIDE 232 RIGHT	7.48	04/09/2021	
21-03-03821-159	185.1-235A	03/10/2021	FOUNTAIN IN NORTH CAFETERIA	4.25	04/09/2021	
21-03-03821-160	185.1-235B	03/10/2021	FOUNTAIN IN NORTH CAFETERIA	5.87	04/09/2021	

Environmental Hazards Services, L.L.C

Client Number: 33-5980

Report Number: 21-03-03821

Project/Test Address: 2020L-185.1; North Tonawanda High School; 405
Meadow Drive; Tonawanda, NY

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
-------------------	------------------	-----------------	---------------------	--------------------------	---------------	--------------

Method: EPA 200.8
Analyst: Anthony Dee
Accreditation #: NY 11714

Reviewed By Authorized Signatory: *Melissa Kanode*

Missy Kanode

QA/QC Clerk

Sample Results denoted with a "less than" (<) sign contain less than the reporting limit which is 1 ppb.

The EPA Maximum Contaminant Level for Lead in Drinking Water is 15 ppb. The results herein conform to NELAC standards, where applicable, unless otherwise narrated on this report. Results represent the analysis of samples submitted by the client. Sample location, description, field parameter results, etc., were provided by the client. This report cannot be reproduced, except in full, without written approval from Environmental Hazards Services, L.L.C.

LEGEND ug/L= micrograms per liter ppb = parts per billion

1.5 Laboratory Certifications

NEW YORK STATE DEPARTMENT OF HEALTH
WADSWORTH CENTER



Expires 12:01 AM April 01, 2022
Issued April 01, 2021
Revised April 02, 2021

CERTIFICATE OF APPROVAL FOR LABORATORY SERVICE

Issued in accordance with and pursuant to section 502 Public Health Law of New York State

MS. JULIE DICKERSON
ENVIRONMENTAL HAZARDS SERVICES, LLC
7469 WHITEPINE ROAD
N. CHESTERFIELD, VA 23237

NY Lab Id No: 11714

*is hereby APPROVED as an Environmental Laboratory in conformance with the
National Environmental Laboratory Accreditation Conference Standards (2016) for the category
ENVIRONMENTAL ANALYSES POTABLE WATER
All approved analytes are listed below:*

Metals I

Arsenic, Total	EPA 200.8 Rev. 5.4
Copper, Total	SM 19, 21-23 3113B (-04,-10) EPA 200.8 Rev. 5.4
Lead, Total	SM 19, 21-23 3113B (-04,-10) EPA 200.8 Rev. 5.4
Manganese, Total	EPA 200.8 Rev. 5.4

NEW YORK
STATE OF
OPPORTUNITY

Department
of Health

Serial No.: 63485

Property of the New York State Department of Health. Certificates are valid only at the address shown, must be conspicuously posted, and are printed on secure paper. Continued accreditation depends on successful ongoing participation in the Program. Consumers are urged to call (518) 485-5570 to verify the laboratory's accreditation status.



1.6 Chains of Custody



Chain of Custody Document

3860 California Road, Orchard Park, New York 14127
 PHONE (716) 312-0070 FAX (716) 312-8092
 WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) EHS
 STOHL Job # 2020L-185.1

Client: North Tonawanda CSD Contact: Jim Hart
 Building: North Tonawanda High School Location: 405 Meadow Drive, Tonawanda, NY

LEAD Turnaround
 Water by SM 19, 21 - 23 3113B (-04, -10) X 20 Days

21-03-03821



Due Date:
 04/14/2021
 (Wednesday)
 AE

Sample #	Location	Outlet Type	Time
185.1-3	Boys' Dressing Room Lead	S	22:37
185.1-4	Boys' Dressing Room Left	S	22:38
185.1-5	Boys' Dressing Room Right	S	22:39
185.1-6	Girls' Dressing Room Lead	S	22:40
185.1-7	Girls' Dressing Room Left	S	22:41
185.1-8	Girls' Dressing Room Right	S	22:42
185.1-9	Outside Dressing Rooms	DF	22:43
185.1-11	Women's Gang Lav Outside New Gym 2nd Left	S	22:44
185.1-12	Women's Gang Lav Outside New Gym 3rd Left	S	22:45
185.1-13	Women's Gang Lav Outside New Gym 3rd Right	S	22:46
185.1-14	Women's Gang Lav Outside New Gym 2nd Right	S	22:47
185.1-15	Women's Gang Lav Outside New Gym Right Most	S	22:48
185.1-16	Men's Gang Lav Outside New Gym Left Most	S	22:49
185.1-17	Men's Gang Lav Outside New Gym 2nd Left	S	22:50
185.1-18	Men's Gang Lav Outside New Gym 3rd Left	S	22:51
185.1-19	Men's Gang Lav Outside New Gym 3rd Right	S	22:52
185.1-20	Men's Gang Lav Outside New Gym 2nd Right	S	22:53
185.1-21	Men's Gang Lav Outside New Gym Right Most	S	22:54

Notes:
 Please e-mail lab results to labs@stohlenv.com If checked, also e-mail results to: Ehenderson@StohlEnv.com

Sampled By: Christine Schultz Print Name Christine Schultz Date: 3/9/2021
 Relinquished By: Eric Henderson Jr. Print Name Eric Henderson Jr. Date: 3/11/2021
 Received (Name / Lab): KTHARRIS K O'Leary Date: 3.17.21 4:00 pm Time: 4:00 pm
 Sample Login (Name / Lab): Traici Blain / Jane Blain Date: 4/16/21 9:14 AM Time: 9:28 AM
 Analysis (Name / Lab): Gary Oca Date: 4/19/21 Time: 5:01 pm
 QA/QC Review (Name / Lab): Melby Date: 4/19/21 Time: 5 pm
 Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____



Chain of Custody Document

3860 California Road, Orchard Park, New York 14127
 PHONE (716) 312-0070 FAX (716) 312-8092
 WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) EHS
 STOHL Job # 2020L-185.1

Client: North Tonawanda CSD Contact: Jim Hart
 Building: North Tonawanda High School Location: 405 Meadow Drive, Tonawanda, NY

LEAD	
Water by SM 19, 21 - 23 3113B (-04, -10) <u>X</u>	Turnaround <u>20 Days</u>

Sample #	Location	Outlet Type	Time
185.1-22	Fountain Outside Gang Lavs Left	DF	22:55
185.1-23	Fountain Outside Gang Lavs Right	DF	22:56
185.1-24	Single Lav Outside New Gym Left	S	22:57
185.1-25	W. Officials	S	22:58
185.1-26	M. Officials	S	22:59
185.1-27A	Fountain Outside New Gym	DF	23:00
185.1-27B	Fountain Outside New Gym	DFB	23:01
185.1-28	Coach/Trainer Office Lav Outside New Gym	S	23:02
185.1-29	Varsity Locker Room Fountain	DF	23:03
185.1-30	Varsity Locker Room Left	S	23:04
185.1-31	Varsity Locker Room Right	S	23:05
185.1-32	New Gym Men's Locker Coach Lav	S	23:06
185.1-33	New Gym Men's Locker Left	S	23:07
185.1-34	New Gym Men's Locker Right	S	23:08
185.1-35	New Gym Women's Locker Coach Lav	S	23:09
185.1-36	New Gym Women's Locker Fountain	DF	23:10
185.1-37	New Gym Women's Locker Left	S	23:11
185.1-39	New Gym Women's Locker Right	S	23:12

Notes:
 Please e-mail lab results to labs@stohlenv.com

Sampled By: Christine Schultz Print Name Christine Schultz Date: 3/9/2021
 Relinquished By: E. Henderson Jr. Print Name Eric Henderson Jr. Date: 3/11/2021
 Received (Name / Lab): KATHARIS JC 20 Date: 3-11-21 Time: 4:00pm
 Sample Login (Name / Lab): Traci Bloomfield Bla Date: 4/6/21 Time: 9:28 Am
 Analysis (Name / Lab): Young Oree Date: 4/9/21 Time: 5:01pm
 QA/QC Review (Name / Lab): Mehul Date: 4/12/21 Time: 5pm
 Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____



Chain of Custody Document

3860 California Road, Orchard Park, New York 14127
 PHONE (716) 312-0070 FAX (716) 312-8092
 WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) EHS
 STOHL Job # 2020L-185.1

Client: North Tonawanda CSD Contact: Jim Hart
 Building: North Tonawanda High School Location: 405 Meadow Drive, Tonawanda, NY

LEAD
 Water by SM 19, 21 - 23 3113B (-04, -10) X Turnaround
20 Days

Sample #	Location	Outlet Type	Time
185.1-43	Old Gym Boys' Locker Left	S	23:13
185.1-45	Old Gym Boys' Locker Coach Office	S	23:14
185.1-46	Fountain Outside Old Gym Girls'	DF	23:15
185.1-47	Old Gym Girls' Locker Coach Office	S	23:16
185.1-48	Old Gym Girls' Locker Left	S	23:17
185.1-49	Old Gym Girls's Locker Right	S	23:18
185.1-50	Corridor Outside 112	DF	23:19
185.1-51	Library	S	23:20
185.1-52	Room 112	S	23:21
185.1-53	Boys' Lav Outside 112 Left	S	23:22
185.1-54	Boys' Lav Outside 112 Center	S	23:23
185.1-55	Boys' Lav Outside 112 Right	S	23:24
185.1-56	Girls' Lav Outside 114 Left	S	23:25
185.1-57	Girls' Lav Outside 114 Center	S	23:26
185.1-58	Girls' Lav Outside 114 Right	S	23:27
185.1-59	1st Floor Men's Faculty	S	23:28
185.1-60	1st Floor Women's Faculty Left	S	23:29
185.1-61	1st Floor Women's Faculty Right	S	23:30

Notes:
 Please e-mail lab results to labs@stohlenv.com

Sampled By: Christine Schultz Print Name Stohl Env: Christine Schultz Date: 3/9/2021
 Relinquished By: E. Henderson Jr. Print Name Stohl Env: Eric Henderson Jr. Date: 3/11/2021
 Received (Name / Lab): KTHARRIS Date: 3.17.21 Time: 4:00pm
 Sample Login (Name / Lab): Traici Bloom / Steve Date: 4/6/21 Time: 9:33 Am
 Analysis (Name / Lab): Young Dae Date: 4/9/21 Time: 5:07 pm
 QA/QC Review (Name / Lab): Melvin Date: 4/12/21 Time: 5pm
 Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____



Chain of Custody Document

3860 California Road, Orchard Park, New York 14127
 PHONE (716) 312-0070 FAX (716) 312-8092
 WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) EHS

STOHL Job # 2020L-185.1

Client: North Tonawanda CSD

Contact: Jim Hart

Building: North Tonawanda High School

Location: 405 Meadow Drive, Tonawanda, NY

LEAD
 Water by SM 19, 21 - 23 3113B (-04, -10) X

Turnaround
20 Days

1 BOTTLE RCVD OPEN - EMPTY (KSB)

Sample #	Location	Outlet Type	Time
185.1-62A	Corridor Outside 1st Floor Women's Faculty	DF	23:31
* 185.1-62B	Corridor Outside 1st Floor Women's Faculty	DFB	23:32
185.1-63	Girls' Lav Outside Cafeteria Left	S	23:33
185.1-65	Girls' Lav Outside Cafeteria Right	S	23:34
185.1-66	Boys' Lav Outside Cafeteria Left	S	23:35
185.1-68	Boys' Lav Outside Cafeteria Right	S	23:36
185.1-69	Room 160 Left	S	23:37
185.1-70	Room 160 Center	S	23:38
185.1-71	Room 160 Right	S	23:39
185.1-72	Room160 Bubbler	B	23:40
185.1-73	Kitchen Serving Handwash	S	23:41
185.1-74	Kitchen Dish Sprayer North Cafe Side	S	23:42
185.1-74.5	Kitchen Single Bay North Cafe Side	S	23:43
185.1-75	Kitchen Handwash North Wall Center Room	S	23:44
185.1-76	Kitchen Single Bay Across from 3 Bay	S	23:45
185.1-77	Kitchen 3 Bay Left	S	23:46
185.1-77.5	Kitchen 3 Bay Right	S	23:47
185.1-78	Kitchen Single Bay Center Prep	S	23:48

Notes:
 Please e-mail lab results to labs@stohlenv.com

Sampled By: Christine Schultz Print Name Christine Schultz Date: 3/9/2021

Relinquished By: Eric Henderson Jr. Print Name Eric Henderson Jr. Date: 3/11/2021

Received (Name / Lab): KTHARBUS Date: 3/17/21 Time: 4:02 PM

Sample Login (Name / Lab): Traoi Blam / Fran Bea Date: 4/6/21 Time: 9:49 AM

Analysis (Name / Lab): Young Ouel Date: 4/9/21 Time: 5:01 pm

QA/QC Review (Name / Lab): Melvin Date: 4/12/21 Time: 5 pm

Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____



Chain of Custody Document

3860 California Road, Orchard Park, New York 14127
 PHONE (716) 312-0070 FAX (716) 312-8092
 WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) EHS

STOHL Job # 2020L-185.1

Client: North Tonawanda CSD

Contact: Jim Hart

Building: North Tonawanda High School

Location: 405 Meadow Drive, Tonawanda, NY

LEAD
 Water by SM 19, 21 - 23 3113B (-04, -10) X

Turnaround
20 Days

Sample #	Location
185.1-79	Kitchen Handwash South Wall Center Room
185.1-80	Kitchen Sish Sprayer South Cafe Side
185.1-80.5	Kitchen Single Bay South Cafe Side
185.1-81	Guidance Office
185.1-82	Room 121
185.1-83	Room 123
185.1-84	Room 122
185.1-85	Room 125
185.1-86	Room 124
185.1-87	Room 126A Left
185.1-89	Room 128
185.1-90	Boys' Lav Outside 130 Left Most
185.1-92	Boys' Lav Outside 130 Center
185.1-94	Boys' Lav Outside 130 Right Most
185.1-95A	Corridor Outside Room 130
185.1-95B	Corridor Outside Room 130
185.1-96	Girls' Lav Outside 130 Left Most
185.1-98	Girls' Lav Outside 130 Center

Outlet Type	Time
S	23:49
S	23:50
S	23:51
S	23:52
S	23:53
S	23:54
S	23:55
S	23:56
S	23:57
S	23:58
S	23:59
S	0:00
S	0:01
S	0:02
DF	0:03
DFB	0:04
S	0:05
S	0:06

Notes:
 Please e-mail lab results to labs@stohlenv.com

Sampled By: Christine Schultz Print Name Christine Schultz Date: 3/9/2021

Relinquished By: E. Henderson Jr. Print Name Eric Henderson Jr. Date: 3/11/2021

Received (Name / Lab): [Signature] Date: 3/12/21 Time: 4:00

Sample Login (Name / Lab): Traici Bloom / Jaci Blen Date: 4/6/21 Time: 10:01 AM

Analysis (Name / Lab): Yong Ose Date: 4/9/21 Time: 5:01 pm

QA/QC Review (Name / Lab): [Signature] Date: 4/12/21 Time: 5 pm

Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____



Chain of Custody Document

3860 California Road, Orchard Park, New York 14127
 PHONE (716) 312-0070 FAX (716) 312-8092
 WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) EHS
 STOHL Job # 2020L-185.1

Client: North Tonawanda CSD Contact: Jim Hart
 Building: North Tonawanda High School Location: 405 Meadow Drive, Tonawanda, NY

LEAD
 Water by SM 19, 21 - 23 3113B (-04, -10) X Turnaround
20 Days

Sample #	Location	Outlet Type	Time
185.1-100	Girls' Lav Outside 130 Right Most	S	0:07
185.1-101	Room 130	S	0:08
185.1-102	Room 132 Northeast	S	0:09
185.1-103	Room 132 Southeast	S	0:10
185.1-104	Room 132 Southwest	S	0:11
185.1-105	Room 132 Northwest	S	0:12
185.1-135	Science Wing Corridor Outside Faculty	DF	0:13
185.1-136	Science Wing Women's Faculty	S	0:14
185.1-137	Science Wing Men's Faculty	S	0:15
185.1-138	Science Wing Girls' Lav Left	S	0:16
185.1-140	Science Wing Girls' Lav Right	S	0:17
185.1-141	Science Wing Boys' Lav Left	S	0:18
185.1-141.5	Science Wing Boys' Lav Center	S	0:19
185.1-142	Science Wing Boys' Lav Right	S	0:20
185.1-143A	Science Wing Corridor Between B/G Lavs	DF	0:21
185.1-143B	Science Wing Corridor Between B/G Lavs	DFB	0:22
185.1-149	Room 151A	S	0:23
185.1-157	Room 155A	S	0:24

Notes:
 Please e-mail lab results to labs@stohlenv.com

Sampled By: Christine Schultz Print Name Christine Schultz Date: 3/9/2021
 Relinquished By: E. Henderson Jr. Print Name Eric Henderson Jr. Date: 3/11/2021
 Received (Name / Lab): K. Glau Date: 3/17/21 Time: 4:00
 Sample Login (Name / Lab): Traei Buent-Ann Bon Date: 4/7/21 Time: 6:54am
 Analysis (Name / Lab): Young Dece Date: 4/9/21 Time: 5:01pm
 QA/QC Review (Name / Lab): Meluh Date: 4/12/21 Time: 5pm
 Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____



Chain of Custody Document

3860 California Road, Orchard Park, New York 14127
 PHONE (716) 312-0070 FAX (716) 312-8092
 WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) EHS

STOHL Job # 2020L-185.1

Client: North Tonawanda CSD

Contact: Jim Hart

Building: North Tonawanda High School

Location: 405 Meadow Drive, Tonawanda, NY

LEAD

Water by SM 19, 21 - 23 3113B (-04, -10) X

Turnaround

20 Days

Sample #	Location	Outlet Type	Time
185.1-166	Room 308 Left	S	0:25
185.1-167	Room 308 Right	S	0:26
185.1-168	Room 307	S	0:27
185.1-169	Room 310	S	0:28
185.1-170	3rd Floor Men's Faculty	S	0:29
185.1-171	3rd Floor Women's Faculty	S	0:30
185.1-172	Boys' Lav Outside 312 Left Most	S	0:31
185.1-174	Boys' Lav Outside 312 Center	S	0:32
185.1-176	Boys' Lav Outside 312 Right Most	S	0:33
185.1-177	Girls' Lav Outside 312 Left Most	S	0:34
185.1-179	Girls' Lav Outside 312 Center	S	0:35
185.1-181	Girls' Lav Outside 312 Right Most	S	0:36
185.1-182A	Corridor Outside 312 Between B/G Lavs	DF	0:37
185.1-182B	Corridor Outside 312 Between B/G Lavs	DFB	0:38
185.1-183	Room 319	S	0:39
185.1-184	Room 322	S	0:40
185.1-189	Room 324 Left	S	0:41
185.1-190	Room 324 Right	S	0:42

Notes:
 Please e-mail lab results to labs@stohlenv.com

Sampled By: Christine Schultz Print Name Christine Schultz Date: 3/9/2021

Relinquished By: Eric Henderson Jr. Print Name Eric Henderson Jr. Date: 3/11/2021

Received (Name / Lab): JK Mann Date: 3/10/21 Time: 4:00 /

Sample Login (Name / Lab): Traici Bloom / Fran Bo Date: 4/7/21 Time: 6:58 AM

Analysis (Name / Lab): Young Osee Date: 4/9/21 Time: 5:01 pm

QA/QC Review (Name / Lab): Melanie Date: 4/12/21 Time: 5p

Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____



Chain of Custody Document

3860 California Road, Orchard Park, New York 14127
 PHONE (716) 312-0070 FAX (716) 312-8092
 WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) EHS

STOHL Job # 2020L-185.1

Client: North Tonawanda CSD Contact: Jim Hart

Building: North Tonawanda High School Location: 405 Meadow Drive, Tonawanda, NY

LEAD		<i>Turnaround</i>
Water by SM 19, 21 - 23 3113B (-04, -10)	<u>X</u>	<u>20 Days</u>

Sample #	Location	Outlet Type	Time
185.1-192	Room 326 Left	S	0:43
185.1-193	Room 326 Right	S	0:44
185.1-194	Room 328	S	0:45
185.1-195	Room 330 North Faucet w/ Hose Attachment	S	0:46
185.1-196	Boys' Lav Outside 332 Left Most	S	0:47
185.1-198	Boys' Lav Outside 332 Center	S	0:48
185.1-200	Boys' Lav Outside 332 Right Most	S	0:49
185.1-201A	Corridor Outside 332 Between B/G Lavs	DF	0:50
185.1-201B	Corridor Outside 332 Between B/G Lavs	DFB	0:51
185.1-202	Girls' Lav Outside 332 Left Most	S	0:52
185.1-204	Girls' Lav Outside 332 Center	S	0:53
185.1-206	Girls' Lav Outside 332 Right Most	S	0:54
185.1-207	Room 332 White Sink Left	S	0:55
185.1-208	Room 332 White Sink Right	S	0:56
185.1-209	Room 332 Far Right	S	0:57
185.1-210	Room 332 Storage	S	0:58
185.1-211	Room 332 Teacher Desk	S	0:59
185.1-212	Room 336	S	1:00

Notes:
 Please e-mail lab results to labs@stohlenv.com

Sampled By: Christine Schultz Print Name Christine Schultz Date: 3/9/2021

Relinquished By: E. Henderson Jr. Print Name Eric Henderson Jr. Date: 3/11/2021

Received (Name / Lab): JK Mann Date: 3/12/21 Time: 4:00

Sample Login (Name / Lab): Traci Bloom / Jani Blo Date: 4/7/21 Time: 7:01 AM

Analysis (Name / Lab): Young Doe Date: 4/9/21 Time: 5:01 pm

QA/QC Review (Name / Lab): Mehul Date: 4/12/21 Time: 5 pm

Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____



Chain of Custody Document

3860 California Road, Orchard Park, New York 14127
 PHONE (716) 312-0070 FAX (716) 312-8092
 WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) EHS

STOHL Job # 2020L-185.1

Client: North Tonawanda CSD

Contact: Jim Hart

Building: North Tonawanda High School

Location: 405 Meadow Drive, Tonawanda, NY

LEAD

Water by SM 19, 21 - 23 3113B (-04, -10) X

Turnaround

20 Days

Sample #	Location	Outlet Type	Time
185.1-213	Boys' Lav Outside 214 Left Most	S	1:01
185.1-215	Boys' Lav Outside 214 Center	S	1:02
185.1-217	Boys' Lav Outside 214 Right Most	S	1:03
185.1-218A	Corridor Outside 214 Between B/G Lavs	DF	1:04
185.1-218B	Corridor Outside 214 Between B/G Lavs	DFB	1:05
185.1-219	Girls' Lav Outside 214 Left Most	S	1:06
185.1-221	Girls' Lav Outside 214 Center	S	1:07
185.1-223	Girls' Lav Outside 214 Right Most	S	1:08
185.1-224	Men's Lav Outside 232 Left Most	S	1:09
185.1-226	Men's Lav Outside 232 Center	S	1:10
* 185.1-228	Men's Lav Outside 232 Right Most	S	1:11
185.1-229A	Corridor Outside 232 Between M/W Lavs	DF	1:12
185.1-229B	Corridor Outside 232 Between M/W Lavs	DFB	1:13
185.1-230	Women's Lav Outside 232 Left Most	S	1:14
185.1-232	Women's Lav Outside 232 Center	S	1:15
185.1-234	Women's Lav Outside 232 Right Most	S	1:16
185.1-235A	Fountain in North Cafeteria	DF	1:17
185.1-235B	Fountain in North Cafeteria	DFB	1:18

BOTTLE REVD OPEN - EMPTY

Notes:

Please e-mail lab results to labs@stohlenv.com

Sampled By: Christine Schultz Print Name Christine Schultz Date: 3/9/2021

Relinquished By: Eric Henderson Jr. Print Name Eric Henderson Jr. Date: 3/11/2021

Received (Name / Lab): JR Mann Date: 3/17/21 Time: 4:00pm

Sample Login (Name / Lab): Tracey Ann / Lisa Ben Date: 4/7/21 Time: 7:05AM

Analysis (Name / Lab): Young Dee Date: 4/9/21 Time: 5:01pm

QA/QC Review (Name / Lab): Melvin Date: 4/14/21 Time: 3pm

Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____

BLANK

The logo for Stohl Environmental features the word "Stohl" in a large, bold, green sans-serif font. A white swoosh underline is positioned beneath the "S" and "t". Below "Stohl", the word "ENVIRONMENTAL" is written in a smaller, grey, all-caps sans-serif font.

Stohl
ENVIRONMENTAL

3860 California Road, Orchard Park, New York 14127

PHONE (716) 312-0070 FAX (716) 312-8092

WWW.STOHLENVIRONMENTAL.COM