

May 13, 2021

Mr. James Hart  
North Tonawanda City School District  
Director of Facilities  
176 Walck Road  
North Tonawanda, New York 14120

**RE: Investigation and Sampling of Drinking Water for Lead Concentrations**

Dear Mr. Hart:

Included with this letter is Stohl Environmental LLC's report for the Water Sampling performed at the educational buildings of the North Tonawanda City School District, including:

- Ohio Elementary – 625 Ohio Street, North Tonawanda, New York.

This report is prepared to assist the District in complying with the requirements of NYS regulations, *SUBPART 67-4: Lead Testing in School Drinking Water*, by identifying the sources of potable water with lead concentrations greater than the NYS "Action Level of 15 parts per billion (ppb)".

The Investigation and Sampling was performed on March 11, 2021. The Protocol for the Investigation followed the requirements of NYS regulations as well as USEPA Technical Guidance Document "3-T's for Reducing Lead in Drinking Water in Schools".

As detailed in Section 1.2 (*Executive Summary*) of the accompanying report, based upon the sampling and analysis performed, 32 sources of potable water in Ohio Elementary School have been identified as having lead concentrations in water above the NYS Action Level of 15 parts per billion. To comply with NYS regulations, Response actions as identified in this report by the District are required.

Thank you for the opportunity to be of service to North Tonawanda City School District.

Sincerely,  
Stohl Environmental, LLC.



Eric Henderson Jr.  
Senior Project Manager

**Investigation and Sampling  
Of Sources of Potable Water  
For Lead Concentrations**

**Prepared for:**

**North Tonawanda City School District**

**Prepared by:**



**3860 California Road, Orchard Park, New York 14127  
PHONE (716) 312-0070 FAX (716) 312-8092  
[WWW.STOHLENVIRONMENTAL.COM](http://WWW.STOHLENVIRONMENTAL.COM)**

**Conditions as of March 11, 2021**

## Summary Tabulation

### Lead in Drinking Water Investigation

- 1.1. Scope of Work and Sampling Protocol
- 1.2. Executive Summary of Sampling and Analysis
- 1.3. Response Actions Required Under NYS Regulations
- 1.4. Laboratory Analytical Reports by Building
- 1.5. Laboratory Certifications
- 1.6. Chains of Custody

## 1.1 Scope of Work and Sampling Protocol:

Stohl Environmental was retained by North Tonawanda City School District to perform sampling and analysis of potable water for elevated lead concentrations. Sampling was performed in the following buildings:

- Ohio Elementary – 625 Ohio Street, North Tonawanda, New York.

### Scope of Work:

Stohl Environmental was charged with collecting first-draw water samples from outlets within Ohio Elementary. Outlets are defined in NYS regulations as: “a potable water fixture currently or potentially used for drinking or cooking purposes, including but not limited to a bubbler, drinking fountain, or faucets”.

### Sampling Protocol:

In accordance with NYS regulations, ***Subpart 67-4: Lead Testing in School Drinking Water***, and the EPA guidance document, ***3Ts for Reducing Lead in Drinking Water in Schools***”, Stohl Environmental’s protocol can be summarized as follows:

- **First-draw samples** of 250 milliliters (mL) were collected from cold water outlets before any water was used. Sampling was coordinated with District representatives to assure that water was motionless in the pipes for a minimum of 8 hours, but not more than 18 hours before sample collection.
- **Laboratory Analysis:** Samples were submitted following strict chain-of-custody protocols to an independent laboratory approved by the NYS Department of Health’s Environmental Laboratory Approval Program (ELAP).

## 1.2 Executive Summary of Sampling and Analysis:

### Total Number of Samples Collected by Building Classified by First Draw & Confirmatory Samples:

Building Name	Date of Sample Event	Total Number Samples Collected	First Draw Samples		Confirmatory Samples **	
			Number of Samples at or Below Action level of 15 ppb	Number of Samples Above Action Level of 15 ppb	Number of Samples at or Below Action level of 15 ppb	Number of Samples Above Action Level of 15 ppb
Ohio Elementary	3/11/2021	90	58	32	N/A	N/A

\*\* Confirmatory samples are samples collected subsequent to “Step 1” First Draw samples to verify initial findings of lead contamination, to assist in problem assessment to determine remediation and/or verify that lead levels are at or below action level post-remediation.

### Listing of Outlets Requiring Remediation

**Locations of Outlets Analyzed above the NYS Action Level of 15 parts per billion based upon Analysis of First Draw Samples:**

Sample #	Classroom or other Location	Fixture/Outlet type	Laboratory Analysis in ppb
185.6-5	Room 114	Sink	15.5
185.6-7	Room 116	Sink	19.0
185.6-8	Room 116	Bubbler	17.0
185.6-10	Room 115	Bubbler	17.8
185.6-11	Boys Locker Room	Bubbler	24.6
185.6-12	Boys Locker Room Left	Sink	21.4
185.6-13	Boys Locker Room Right	Sink	18.5
185.6-14	Girls Locker Room	Bubbler	22.5
185.6-15	Girls Locker Room Left	Sink	31.1
185.6-16	Girls Locker Room Right	Sink	41.4
185.6-23	Room 118	Sink	25.0
185.6-24	Room 118	Bubbler	42.3
185.6-25	Room 117	Sink	26.9
185.6-26	Room 117	Bubbler	21.6
185.6-28	Room 120	Bubbler	49.8
185.6-29	Room 119	Sink	16.6
185.6-31	Room 122	Sink	19.9
185.6-36	Room 124	Bubbler	39.8
185.6-37	Room 126	Sink	20.7
185.6-39	Room 123	Sink	26.3
185.6-40	Room 123	Bubbler	27.8
185.6-41	Room 125	Sink	16.8
185.6-43	Room 127	Sink	45.2
185.6-44	Room 128	Sink	27.4
185.6-60	Room 112	Sink	51.4
185.6-79	Room 109 Main	Sink	22.7
185.6-82	Room 108 Main	Sink	16.5
185.6-83	Room 108	Sink	191
185.6-85	Room 107 Main	Sink	112
185.6-86	Room 107	Bubbler	20.7
185.6-88	Room 106 Main	Sink	16.3
185.6-104	Room 101	Bubbler	15.8

### **1.3 Response Actions Required Under NYS Regulations, Section 67-4.4:**

For outlets analyzed with a lead concentration in excess of the NYS Action Level, regulations require:

- (a) Prohibit use of the outlet until:
  - (1) a lead remediation plan is implemented to mitigate the lead level of such outlet; and
  - (2) test results indicate that the lead levels are at or below the action level;
- (b) provide building occupants with an adequate supply of potable water for drinking and cooking until remediation is performed;
- (c) report the test results to the local health department as soon as practicable, but no more than 1 business day after the school received the laboratory report; and
- (d) notify all staff and all persons in parental relation to students of the test results, in writing, as soon as practicable but no more than 10 business days after the school received the laboratory report.

#### 1.4 Laboratory Analytical Reports by Building





Environmental Hazards Services, L.L.C.  
7469 Whitepine Rd  
Richmond, VA 23237  
Telephone: 800.347.4010

## Lead in Drinking Water Analysis Report

Client: Stohl Environmental  
3860 California Road  
Orchard Park, NY 14127

Report Number: 21-03-03455

Received Date: 03/16/2021  
Reported Date: 04/09/2021  
Sampled By: Christine Schultz  
Tech Certification #:

Project/Test Address: 2020L-185.6; Ohio Elementary; 625 Ohio Street

Client Number:  
33-5980

# Laboratory Results

Fax Number:  
716-312-8092

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
21-03-03455-001	185.6-5	03/11/2021	114	15.5	04/07/2021	
21-03-03455-002	185.6-6	03/11/2021	114	10.7	04/07/2021	
21-03-03455-003	185.6-7	03/11/2021	116	19.0	04/07/2021	
21-03-03455-004	185.6-8	03/11/2021	116	17.0	04/07/2021	
21-03-03455-005	185.6-9	03/11/2021	115	14.0	04/07/2021	
21-03-03455-006	185.6-10	03/11/2021	115	17.8	04/07/2021	
21-03-03455-007	185.6-11	03/11/2021	BOYS LOCKER ROOM	24.6	04/07/2021	
21-03-03455-008	185.6-12	03/11/2021	BOYS LOCKER ROOM LEFT	21.4	04/07/2021	
21-03-03455-009	185.6-13	03/11/2021	BOYS LOCKER ROOM RIGHT	18.5	04/07/2021	
21-03-03455-010	185.6-14	03/11/2021	GIRLS LOCKER ROOM	22.5	04/07/2021	
21-03-03455-011	185.6-15	03/11/2021	GIRLS LOCKER ROOM LEFT	31.1	04/07/2021	
21-03-03455-012	185.6-16	03/11/2021	GIRLS LOCKER ROOM RIGHT	41.4	04/07/2021	
21-03-03455-013	185.6-17	03/11/2021	GIRLS RESTROOM LEFT	13.0	04/07/2021	

# Environmental Hazards Services, L.L.C

Client Number: 33-5980

Report Number: 21-03-03455

Project/Test Address: 2020L-185.6; Ohio Elementary; 625 Ohio Street

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
21-03-03455-014	185.6-18	03/11/2021	GIRL RESTROOM 2ND LEFT	8.90	04/07/2021	
21-03-03455-015	185.6-19	03/11/2021	GIRL RESTROOM CENTER	6.65	04/07/2021	
21-03-03455-016	185.6-20	03/11/2021	GIRL RESTROOM 2ND RIGHT	2.96	04/07/2021	
21-03-03455-017	185.6-21	03/11/2021	GIRL RESTROOM RIGHT	2.66	04/07/2021	
21-03-03455-018	185.6-22B	03/11/2021	HALLWAY ACROSS FROM GIRLS LOCKER	1.15	04/07/2021	
21-03-03455-019	185.6-23	03/11/2021	118	25.0	04/08/2021	
21-03-03455-020	185.6-24	03/11/2021	118	42.3	04/07/2021	
21-03-03455-021	185.6-25	03/11/2021	117	26.9	04/07/2021	
21-03-03455-022	185.6-26	03/11/2021	117	21.6	04/07/2021	
21-03-03455-023	185.6-27	03/11/2021	120	12.8	04/07/2021	
21-03-03455-024	185.6-28	03/11/2021	120	49.8	04/07/2021	
21-03-03455-025	185.6-29	03/11/2021	119	16.6	04/07/2021	
21-03-03455-026	185.6-31	03/11/2021	122	19.9	04/07/2021	
21-03-03455-027	185.6-32	03/11/2021	122	13.8	04/07/2021	
21-03-03455-028	185.6-35	03/11/2021	124	14.6	04/07/2021	
21-03-03455-029	185.6-36	03/11/2021	124	39.8	04/07/2021	
21-03-03455-030	185.6-37	03/11/2021	126	20.7	04/07/2021	
21-03-03455-031	185.6-39	03/11/2021	123	26.3	04/07/2021	
21-03-03455-032	185.6-40	03/11/2021	123	27.8	04/07/2021	
21-03-03455-033	185.6-41	03/11/2021	125	16.8	04/07/2021	

# Environmental Hazards Services, L.L.C

Client Number: 33-5980

Report Number: 21-03-03455

Project/Test Address: 2020L-185.6; Ohio Elementary; 625 Ohio Street

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
21-03-03455-034	185.6-43	03/11/2021	127	45.2	04/07/2021	
21-03-03455-035	185.6-44	03/11/2021	128	27.4	04/07/2021	
21-03-03455-036	185.6-45B	03/11/2021	HALLWAY AROUND CORNER FROM 129	<1.00	04/07/2021	
21-03-03455-037	185.6-46	03/11/2021	GIRLS BATHROOM AROUND CORNER FROM 129 LEFT	<1.00	04/07/2021	
21-03-03455-038	185.6-47	03/11/2021	GIRLS BATHROOM AROUND CORNER FROM 129 RIGHT	<1.00	04/07/2021	
21-03-03455-039	185.6-48	03/11/2021	BOYS BATHROOM AROUND CORNER FROM 129 LEFT	<1.00	04/07/2021	
21-03-03455-040	185.6-49	03/11/2021	BOYS BATHROOM AROUND CORNER FROM 129 RIGHT	<1.00	04/07/2021	
21-03-03455-041	185.6-50	03/11/2021	WOMEN'S BATHROOM BY 129	<1.00	04/07/2021	
21-03-03455-042	185.6-51	03/11/2021	MEN'S BATHROOM BY 129	<1.00	04/07/2021	
21-03-03455-043	185.6-52	03/11/2021	BOYS BATHROOM BY 150 LEFT	3.91	04/07/2021	
21-03-03455-044	185.6-53	03/11/2021	BOYS BATHROOM BY 150 2ND LEFT	4.33	04/07/2021	
21-03-03455-045	185.6-54	03/11/2021	BOYS BATHROOM BY 150 CENTER	3.22	04/07/2021	
21-03-03455-046	185.6-55	03/11/2021	BOYS BATHROOM BY 150 2ND RIGHT	12.4	04/07/2021	
21-03-03455-047	185.6-56	03/11/2021	BOYS BATHROOM BY 150 RIGHT	5.00	04/07/2021	
21-03-03455-048	185.6-57	03/11/2021	MEN BATHROOM IN 150	6.12	04/07/2021	
21-03-03455-049	185.6-58	03/11/2021	WOMEN'S BATHROOM IN 150 LEFT	4.18	04/07/2021	
21-03-03455-050	185.6-59	03/11/2021	WOMEN'S BATHROOM IN 150 RIGHT	7.87	04/08/2021	
21-03-03455-051	185.6-60	03/11/2021	112	51.4	04/08/2021	
21-03-03455-052	185.6-62	03/11/2021	HEALTH OFFICE	4.98	04/08/2021	
21-03-03455-053	185.6-63	03/11/2021	HEALTH OFFICE LAV	<1.00	04/08/2021	

# Environmental Hazards Services, L.L.C

Client Number: 33-5980

Report Number: 21-03-03455

Project/Test Address: 2020L-185.6; Ohio Elementary; 625 Ohio Street

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
21-03-03455-054	185.6-64	03/11/2021	111	6.19	04/08/2021	
21-03-03455-055	185.6-65B	03/11/2021	HALLWAY OUTSIDE 111	1.05	04/08/2021	
21-03-03455-056	185.6-66	03/11/2021	MAIN OFFICE	10.1	04/08/2021	
21-03-03455-057	185.6-67	03/11/2021	WOMEN'S BATHROOM OUTSIDE MAIN OFFICE	3.78	04/08/2021	
21-03-03455-058	185.6-68	03/11/2021	MEN'S BATHROOM OUTSIDE MAIN OFFICE	5.09	04/08/2021	
21-03-03455-059	185.6-69B	03/11/2021	CAFETERIA	2.68	04/08/2021	
21-03-03455-060	185.6-70	03/11/2021	KITCHEN DISH SPRAYER	11.3	04/08/2021	
21-03-03455-061	185.6-71	03/11/2021	KITCHEN 3 BAY LEFT	1.72	04/08/2021	
21-03-03455-062	185.6-72	03/11/2021	KITCHEN 3 BAY RIGHT	7.84	04/08/2021	
21-03-03455-063	185.6-73	03/11/2021	KITCHEN LAV	4.47	04/08/2021	
21-03-03455-064	185.6-74	03/11/2021	KITCHEN HANDWASH	5.45	04/08/2021	
21-03-03455-065	185.6-76	03/11/2021	110 MAIN	6.10	04/08/2021	
21-03-03455-066	185.6-78	03/11/2021	110 LAV	2.94	04/08/2021	
21-03-03455-067	185.6-79	03/11/2021	109 MAIN	22.7	04/08/2021	
21-03-03455-068	185.6-80	03/11/2021	109	12.7	04/08/2021	
21-03-03455-069	185.6-81	03/11/2021	109 LAV	3.04	04/08/2021	
21-03-03455-070	185.6-82	03/11/2021	108 MAIN	16.5	04/08/2021	
21-03-03455-071	185.6-83	03/11/2021	108	191	04/08/2021	
21-03-03455-072	185.6-84	03/11/2021	108 LAV	5.86	04/08/2021	
21-03-03455-073	185.6-85	03/11/2021	107 MAIN	112	04/08/2021	

# Environmental Hazards Services, L.L.C

Client Number: 33-5980

Report Number: 21-03-03455

Project/Test Address: 2020L-185.6; Ohio Elementary; 625 Ohio Street

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
21-03-03455-074	185.6-6	03/11/2021	107	20.7	04/08/2021	
21-03-03455-075	185.6-87	03/11/2021	107 LAV	4.04	04/08/2021	
21-03-03455-076	185.6-88	03/11/2021	106 MAIN	16.3	04/08/2021	
21-03-03455-077	185.6-89	03/11/2021	106	14.1	04/08/2021	
21-03-03455-078	185.6-90	03/11/2021	106 LAV	2.67	04/08/2021	
21-03-03455-079	185.6-91	03/11/2021	105 MAIN	4.04	04/08/2021	
21-03-03455-080	185.6-92	03/11/2021	105	10.4	04/08/2021	
21-03-03455-081	185.6-93	03/11/2021	105 LAV	3.84	04/08/2021	
21-03-03455-082	185.6-94	03/11/2021	104 MAIN	<1.00	04/08/2021	
21-03-03455-083	185.6-96	03/11/2021	104 LAV	<1.00	04/08/2021	
21-03-03455-084	185.6-97	03/11/2021	103 MAIN	7.69	04/08/2021	
21-03-03455-085	185.6-99	03/11/2021	103 LAV	3.51	04/08/2021	
21-03-03455-086	185.6-100	03/11/2021	102 MAIN	5.47	04/08/2021	
21-03-03455-087	185.6-102	03/11/2021	102 LAV	8.00	04/08/2021	
21-03-03455-088	185.6-103	03/11/2021	101 MAIN	14.7	04/08/2021	
21-03-03455-089	185.6-104	03/11/2021	101	15.8	04/08/2021	
21-03-03455-090	185.6-105	03/11/2021	101 LAV	5.66	04/08/2021	

# Environmental Hazards Services, L.L.C

Client Number: 33-5980

Report Number: 21-03-03455

Project/Test Address: 2020L-185.6; Ohio Elementary; 625 Ohio Street

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
----------------------	---------------------	--------------------	---------------------	-----------------------------	------------------	-----------------

Method: EPA 200.8

Analyst: Anthony Dee

Accreditation #: NY 11714

Reviewed By Authorized Signatory: *Melissa Kanode*

*Missy Kanode*

QA/QC Clerk

Sample Results denoted with a "less than" (<) sign contain less than the reporting limit which is 1 ppb.

The EPA Maximum Contaminant Level for Lead in Drinking Water is 15 ppb. The results herein conform to NELAC standards, where applicable, unless otherwise narrated on this report. Results represent the analysis of samples submitted by the client. Sample location, description, field parameter results, etc., were provided by the client. This report cannot be reproduced, except in full, without written approval from Environmental Hazards Services, L.L.C.

LEGEND                      ug/L= micrograms per liter                      ppb = parts per billion

## 1.5 Laboratory Certifications



NEW YORK STATE DEPARTMENT OF HEALTH  
WADSWORTH CENTER



Expires 12:01 AM April 01, 2022  
Issued April 01, 2021  
Revised April 02, 2021

**CERTIFICATE OF APPROVAL FOR LABORATORY SERVICE**

*Issued in accordance with and pursuant to section 502 Public Health Law of New York State*

MS. JULIE DICKERSON  
ENVIRONMENTAL HAZARDS SERVICES, LLC  
7469 WHITEPINE ROAD  
N. CHESTERFIELD, VA 23237

NY Lab Id No: 11714

*is hereby APPROVED as an Environmental Laboratory in conformance with the  
National Environmental Laboratory Accreditation Conference Standards (2016) for the category  
ENVIRONMENTAL ANALYSES POTABLE WATER  
All approved analytes are listed below:*

**Metals I**

Arsenic, Total	EPA 200.8 Rev. 5.4
Copper, Total	SM 19, 21-23 3113B (-04,-10) EPA 200.8 Rev. 5.4
Lead, Total	SM 19, 21-23 3113B (-04,-10) EPA 200.8 Rev. 5.4
Manganese, Total	EPA 200.8 Rev. 5.4

NEW YORK  
STATE OF  
OPPORTUNITY.

Department  
of Health

Serial No.: 63485

Property of the New York State Department of Health. Certificates are valid only at the address shown, must be conspicuously posted, and are printed on secure paper. Continued accreditation depends on successful ongoing participation in the Program. Consumers are urged to call (518) 485-5570 to verify the laboratory's accreditation status.





**1.6 Chains of Custody**



## Chain of Custody Document

3860 California Road, Orchard Park, New York 14127  
PHONE (716) 312-0070 FAX (716) 312-8092  
WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) EHS

STOHL Job # 2020L-185.6

Client: North Tonawanda CSD

Contact: Jim Hart

Building: Ohio Elementary

Location: 625 Ohio Street

### LEAD

Water by SM 19, 21 - 23 3113B (-04, -10)

X

Turnaround

20 Days

Sample #	Location	Outlet Type	Time
185.6-5	114	s	4:20
185.6-6	114	b	4:21
185.6-7	116	s	4:22
185.6-8	116	b	4:23
185.6-9	115	s	4:24
185.6-10	115	b	4:25
185.6-11	boys locker room	B	4:26
185.6-12	boys locker room left	s	4:27
185.6-13	boys locker room right	s	4:28
185.6-14	girls locker room	b	4:29
185.6-15	girls locker room left	s	4:30
185.6-16	girls locker room right)	s	4:31
185.6-17	Girl restroom left	S	4:32
185.6-18	Girl restroom 2nd left	S	4:33
185.6-19	Girl restroom center	S	4:34
185.6-20	Girl restroom 2nd right	S	4:35
185.6-21	Girl restroom right	S	4:36
185.6-22B	hallway across from girls locker	dfb	4:37

21-03-03455



Due Date:  
04/13/2021  
(Tuesday)  
AE

### Notes:

Please e-mail lab results to [labs@stohlenvironment.com](mailto:labs@stohlenvironment.com)

☒ If checked, also e-mail results to:

[Ehenderson@StohlEnv.com](mailto:Ehenderson@StohlEnv.com)

Sampled By: Christine Schultz Print Name Christine Schultz Date: 3/11/2021

Relinquished By: Eric Henderson Jr. Print Name Eric Henderson Jr. Date: 3/12/2021

Received (Name / Lab): KTHARRIS K. Vane Date: 3-16-21 Time: 3:40 pm

Sample Login (Name / Lab): Aminda Lavery A. Jones Date: 4/6/21 Time: 8:21 AM

Analysis (Name / Lab): Young Doe Date: 4/12/21 Time: 2:22 AM

QA/QC Review (Name / Lab): Melvin Date: 4/12/21 Time: 5pm

Archived / Released: \_\_\_\_\_ QA/QC InterLAB Use: \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_



3860 California Road, Orchard Park, New York 14127  
PHONE (716) 312-0070 FAX (716) 312-8092  
WWW.STOHLENVIRONMENTAL.COM

## Chain of Custody Document

Submitted to: (Lab Name) EHS

STOHL Job # 2020L-185.6

Client: North Tonawanda CSD

Contact: Jim Hart

Building: Ohio Elementary

Location: 625 Ohio Street

### LEAD

Water by SM 19, 21 - 23 3113B (-04, -10)

X

Turnaround

20 Days

Sample #	Location	Outlet Type	Time
185.6-23	118	s	4:38
185.6-24	118	b	4:39
185.6-25	117	s	4:40
185.6-26	117	b	4:41
185.6-27	120	s	4:42
185.6-28	120	b	4:43
185.6-29	119	s	4:44
185.6-31	122	s	4:45
185.6-32	122	b	4:46
185.6-35	124	s	4:47
185.6-36	124	b	4:48
185.6-37	126	s	4:49
185.6-39	123	s	4:50
185.6-40	123	B	4:51
185.6-41	125	s	4:52
185.6-43	127	s	4:53
185.6-44	128	S	4:54
185.6-45B	hallway around corner from 129	dfb	4:55

### Notes:

Please e-mail lab results to [labs@stohlenvironmental.com](mailto:labs@stohlenvironmental.com)

Sampled By: Christine Schultz Print Name Christine Schultz Date: 3/11/2021

Relinquished By: Eric Henderson Jr. Print Name Eric Henderson Jr. Date: 3/12/2021

Received (Name / Lab): KT HARRIS Date: 3-16-21 Time: 3:40 pm

Sample Login (Name / Lab): Amanda Lowery Date: 4/6/21 Time: 8:38 AM

Analysis (Name / Lab): Young Doe Date: 4/12/21 Time: 2:22 pm

QA/QC Review (Name / Lab): Melinda Date: 4/12/21 Time: 5 pm

Archived / Released: \_\_\_\_\_ QA/QC InterLAB Use: \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_



3860 California Road, Orchard Park, New York 14127  
PHONE (716) 312-0070 FAX (716) 312-8092  
WWW.STOHLNENVIRONMENTAL.COM

## Chain of Custody Document

Submitted to: (Lab Name) EHS

STOHL Job # 2020L-185.6

Client: North Tonawanda CSD

Contact: Jim Hart

Building: Ohio Elementary

Location: 625 Ohio Street

### LEAD

Water by SM 19, 21 - 23 3113B (-04, -10) X

Turnaround

20 Days

Sample #	Location	Outlet Type	Time
185.6-46	girls bathroom around corner from 129 left	s	4:56
185.6-47	girls bathroom around corner from 129 right	s	4:57
185.6-48	boys bathroom around corner from 129 left	s	4:58
185.6-49	boys bathroom around corner from 129 right	s	4:59
185.6-50	women's bathroom by 129	s	5:00
185.6-51	men's bathroom by 129	s	5:01
185.6-52	boys bathroom by 150 left	S	5:02
185.6-53	boys bathroom by 150 2nd left	S	5:03
185.6-54	boys bathroom by 150 center	S	5:04
185.6-55	boys bathroom by 150 2nd right	S	5:05
185.6-56	boys bathroom by 150 right	S	5:06
185.6-57	men bathroom in 150	S	5:07
185.6-58	women's bathroom in 150 left	s	5:08
185.6-59	women's bathroom in 150 right	s	5:09
185.6-60	112	s	5:10
185.6-62	health office	s	5:11
185.6-63	health office lav	s	5:12
185.6-64	111	s	5:13

### Notes:

Please e-mail lab results to labs@stohlenv.com

Sampled By: Christine Schultz Print Name Stohl Env: Christine Schultz Date: 3/11/2021

Relinquished By: Eric Henderson Jr. Print Name Stohl Env: Eric Henderson Jr. Date: 3/12/2021

Received (Name / Lab): K. THARRIS Date: 3.16.21 Time: 3:40 pm

Sample Login (Name / Lab): Amanda Lowery Date: 4/6/21 Time: 9:07 AM

Analysis (Name / Lab): Young Doe Date: 4/1/21 Time: 2:22 PM

QA/QC Review (Name / Lab): Melinda Date: 4/1/21 Time: 5pm

Archived / Released: \_\_\_\_\_ QA/QC InterLAB Use: \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_



3860 California Road, Orchard Park, New York 14127  
 PHONE (716) 312-0070 FAX (716) 312-8092  
 WWW.STOHLENVIRONMENTAL.COM

## Chain of Custody Document

Submitted to: (Lab Name) EHS

STOHL Job # 2020L-185.6

Client: North Tonawanda CSD

Contact: Jim Hart

Building: Ohio Elementary

Location: 625 Ohio Street

### LEAD

Water by SM 19, 21 - 23 3113B (-04, -10) X

Turnaround

20 Days

Sample #	Location	Outlet Type	Time
185.6-65B	hallway outside 111	dfb	5:14
185.6-66	Main office	s	5:15
185.6-67	Women's bathroom outside main office	s	5:16
185.6-68	men's bathroom outside main office	s	5:17
185.6-69B	cafeteria	dfb	5:18
185.6-70	Kitchen dish sprayer	S	5:19
185.6-71	Kitchen 3 Bay Left	S	5:20
185.6-72	Kitchen 3 Bay Right	s	5:21
185.6-73	Kitchen lav	s	5:22
185.6-74	Kitchen Handwash	S	5:23
185.6-76	110 main	S	5:24
185.6-78	110 lav	s	5:25
185.6-79	109 main	s	5:26
185.6-80	109	b	5:27
185.6-81	109 lav	s	5:28
185.6-82	108 main	s	5:29
185.6-83	108	B	5:30
185.6-84	108 lav	s	5:31

### Notes:

Please e-mail lab results to labs@stohlenv.com

Sampled By: Christine Schultz Print Name Christine Schultz Date: 3/11/2021

Relinquished By: Eric Henderson Jr. Print Name Eric Henderson Jr. Date: 3/12/2021

Received (Name / Lab): KT HARRIS Date: 3.16.21 Time: 3:40 pm

Sample Login (Name / Lab): Amarda Lowery Date: 4/6/21 Time: 9:17 AM

Analysis (Name / Lab): Young Ode Date: 4/12/21 Time: 2:22 pm

QA/QC Review (Name / Lab): Melinda Date: 4/12/21 Time: 5 pm

Archived / Released: \_\_\_\_\_ QA/QC InterLAB Use: \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_



3860 California Road, Orchard Park, New York 14127  
PHONE (716) 312-0070 FAX (716) 312-8092  
WWW.STOHLENVIRONMENTAL.COM

## Chain of Custody Document

Submitted to: (Lab Name) EHS

STOHL Job # 2020L-185.6

Client: North Tonawanda CSD

Contact: Jim Hart

Building: Ohio Elementary

Location: 625 Ohio Street

### LEAD

Water by SM 19, 21 - 23 3113B (-04, -10) X

Turnaround

20 Days

Sample #	Location	Outlet Type	Time
185.6-85	107 main	s	5:32
185.6-86	107	b	5:33
185.6-87	107 lav	S	5:34
185.6-88	106 main	s	5:35
185.6-89	106	b	5:36
185.6-90	106 lav	s	5:37
185.6-91	105 main	s	5:38
185.6-92	105	b	5:39
185.6-93	105 lav	s	5:40
185.6-94	104main	s	5:41
185.6-96	104 lav	s	5:42
185.6-97	103 main	s	5:43
185.6-99	103 lav	s	5:44
185.6-100	102 main	s	5:45
185.6-102	102 lav	s	5:46
185.6-103	101 main	s	5:47
185.6-104	101	b	5:48
185.6-105	101 lav	s	5:49

### Notes:

Please e-mail lab results to labs@stohlenvironmental.com

Sampled By: Christine Schultz Print Name Christine Schultz Date: 3/11/2021

Relinquished By: E. Henderson Jr. Print Name Eric Henderson Jr. Date: 3/12/2021

Received (Name / Lab): KT HARRIS Date: 3-16-21 Time: 3:40 pm

Sample Login (Name / Lab): A Lowery Date: 4/16/21 Time: 9:24 AM

Analysis (Name / Lab): Sperry Ode Date: 4/16/21 Time: 2:22 pm

QA/QC Review (Name / Lab): Melinda Date: 4/16/21 Time: 5 pm

Archived / Released: \_\_\_\_\_ QA/QC InterLAB Use: \_\_\_\_\_ Date: \_\_\_\_\_ Time: \_\_\_\_\_

BLANK



**3860 California Road, Orchard Park, New York 14127**

**PHONE (716) 312-0070 FAX (716) 312-8092**

**[WWW.STOHLENVIRONMENTAL.COM](http://WWW.STOHLENVIRONMENTAL.COM)**